

**ADDENDA**

**ADDENDUM NUMBER (2)**

Date: 2/12/2020

PROJECT : Jones Ferry Road WTP Finished Water Distribution Resiliency Improvements

OWASA CIP NUMBER: 275-92

OWNER: ORANGE WATER AND SEWER AUTHORITY

ENGINEER: Hazen & Sawyer

To All Bidders:

Contractors submitting proposals for the above named project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's Bid Proposal.

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated Jan/2020, Addendum Number 1 issued Feb/2020, with amendments and additions noted herein and below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 2 pages:

**The return receipt requested with the communication will be deemed evidence the bidder has received this Addendum and has followed the instructions outlined herein. Please sign, date, clearly print company name, and email this sheet back to Hazen and Sawyer, [mmiles@hazenandsawyer.com](mailto:mmiles@hazenandsawyer.com)**

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Acknowledgement of Receipt

\_\_\_\_\_  
Date



\_\_\_\_\_  
Matthew C. Miles, P.E.  
HAZEN AND SAWYER

**ORANGE WATER AND SEWER AUTHORITY**  
**CARRBORO, NORTH CAROLINA**  
**Jones Ferry Road WTP FW Resiliency Improvements**  
**Addendum No. 2**

**Contract Specifications:**

11220-STATIC MIXING EQUIPMENT

1. Section 1.01.A
  - Replace 36-inch with 30-inch.

**Contract Drawings:**

C04 – Demolition Plan

Add the following note:

4. CONTRACTOR SHALL REMOVE EXISTING BRADFORD PEAR LABELED 14MG IN THE VICINITY OF THE SOUTHEAST CORNER OF THE FINISHED WATER CLEARWELL ALONG WITH THE EXISTING MONITORING WELL ADJACENT TO TREE 14MG. MONITORING WELL SHALL BE REMOVED AND FILLED WITH GROUT.