Orange Water and Sewer Authority

OWASA is Carrboro-Chapel Hill's not-for-profit public service agency delivering high quality water, wastewater, and reclaimed water services.

ADDENDA

ADDENDUM NUMBER 02

DATE: DECEMBER 17, 2021

PROJECT: GRAVITY SEWER REHABILITATION PACKAGE NO. 6

OWASA CIP NUMBER: 276-18

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL BIDDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated November 2021, Addendum Number 02, issued December 17, 2021, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 2 pages:

RESPONSES TO BIDDER QUESTIONS:

1. **Are there any minority/MBE/WBE requirements for this project?**
   Response: *A documented good faith effort to locate minority/MBE/WBE companies and suppliers is required, however, there is not a specific percentage participation requirement. See previously released bid documents for additional information and forms.*

2. **What is the estimated budget for this project?**
   Response: *No budget estimate is available for this project.*

3. **What are the debris disposal requirements?**
   Response: *The Contractor is responsible for disposal all debris and waste resulting from their work and work performed by their subcontractors. Disposal of debris and waste shall be as required under Federal, State, and Local laws and regulation based on the type of material.*

4. **Are there any CCTV Videos available of the project area?**
   Response: *Videos will be shared as information only and are not part of the bid or contract documents.*

5. **Does the Post CCTV Video need to be done after the Manhole Rehab?**
   Response: *Post CCTV Video is only required for CIPP lining. Detailed photos of the completed manhole rehab are acceptable.*

6. **Is a bid bond required for this project?**
   Response: *A bid bond is not required.*

7. **Our manhole Rehabilitation partner asks - It states in the spec that the manholes are to be sand blasted and looking at the plans it looks like they are in high traffic areas, which would add an extra step to our process. We have done work in Carrboro in the past and have never done any sand blasting. Do you think high pressure water blasting would be acceptable?**
   Response: *Sand blasting is the required for manholes rehab prior to coating. High pressure water blasting is not an approved alternative to sand blasting.*

CHANGES TO THE SPECIFICATIONS:

1. No changes.

CHANGES TO THE DRAWINGS:

1. No changes.

-END OF DOCUMENT-