Addendum No. 1 To RFP

Project: Material Procurement – Scarlett-Cooper

Owner: Orange Water and Sewer Authority

Date: July 7, 2022

To All Bidders:

For the above named project, please take note of the following changes, additions, deletions, clarifications, etc., in the request for proposal which shall become a part of and have precedence over anything contrarily shown or described in the request for proposal documents, and all such shall be taken into consideration and be included in the bid proposal.

- OWASA will accept either domestic or imported fittings
- OWASA will accept either flex -ring restrained joint DIP or slip-joint DIP with restrained joint gaskets. Please price both options and note the availability of each (shipment times).

The return receipt requested will be deemed evidence the bidder received this addendum and has followed the instructions herein. Please send a return email to Allison Spinelli (aspinelli@owasa.org) to confirm receipt of the addendum.

Allison Spinelli, PE

Engineering Manager-CIP

7/7/2022