ADDENDUM NUMBER 02

DATE: OCTOBER 4, 2022

PROJECT: GRAVITY SEWER REHABILITATION PACKAGE NO. 8

OWASA CIP NUMBER: 276-18

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL PLANHOLDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated September 19, 2022, Addendum Number 01 issued September 22, 2022, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 pages:

CHANGES TO THE SPECIFICATIONS: **NONE**

CHANGES TO THE DRAWINGS: **NONE**

BIDDERS' QUESTIONS:

1. Question: Is there a pre-bid meeting?

   Response: There will be no pre-bid meeting scheduled.

2. Question: Are Manhole Frames and Covers going to be replaced for all rehabilitated MHs?

   Response: No frames and covers are intended to be replaced.

3. Question: Will flow thru plugs be permitted in lieu of bypassing for Manhole Rehabilitation?

   Response:. Contractor is responsible for the work, including but not limited to, planning, traffic control measures, adhering to applicable laws and regulations, furnishing all necessary equipment, materials, labor, and appurtenances, and employing appropriate means and methods to accomplish the work. Contractor will be held responsible for the failure to accomplish the required work, including but not limited to preventing sewer spills.

-END OF DOCUMENT-

NORTH CAROLINA PROFESSIONAL SEAL 046866 ENGINEER BRADFORD W. BARBER 10/04/2022