

ADDENDUM NUMBER 02

DATE: February 19, 2024

PROJECT: GRAVITY SEWER REHABILITATION PACKAGE NO. 12

OWASA CIP NUMBER: 276-18

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL PLANHOLDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated January 19, 2024, Addendum Number 02 issued February 19, 2024, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 page(s):

CHANGES TO THE SPECIFICATIONS:

1. No changes.

BIDDERS' QUESTIONS:

1. Question: "Is Saertex S+ UV Cure Liner an acceptable lining system?"

Response: Yes, but contractors must request permission from the Owner/Engineer to use UV cure methods in writing.

2. Question: "Are any specific working hours for this project due to the Elementary School adjacent to the jobsite?"

Response: In accordance with section General Conditions paragraph 7.02, regular working hours are 7:00 am – 6:00pm Monday through Friday. The Town of Carrboro may place additional working hour limitations based on their requirements on the project through their Traffic Control and Lane Closure permitting process. The contractor is responsible for obtaining Traffic Control and Lane Closure permits from the Town for the project. The contractor may request, in writing at least 48 hrs in advance, permission to work outside the regular working hours from the Owner.

3. Question: "Are there any Frocemains feeding into the pipe segments?"

Response: No, the project area consists of a gravity sewer system.

-END OF DOCUMENT-

Gravity Sewer Rehab. Package No. 12



Orange Water & Sewer Authority

Addendum No. 2