

ADDENDUM NUMBER 03

DATE: February 21, 2024

PROJECT: GRAVITY SEWER REHABILITATION PACKAGE NO. 13

OWASA CIP NUMBER: 276-18

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL PLANHOLDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated January 19, 2024, Addendum Number 03 issued February 21, 2024, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 page(s):

CHANGES TO THE SPECIFICATIONS: **NONE**

CHANGES TO THE DRAWINGS: **NONE**

BIDDERS' QUESTIONS:

1. Question: "Section 02651 Closed-Circuit Television Inspection – The specifications states that all video CCTV inspection shall be submitted in WinCAN format, and that the software used on the inspection truck must be WinCAN. Additionally, the specification calls for a PACP version 4.2 export file, which is significantly outdated. Will the Owner allow for the videos to be completed in a different inspection software and provide the Owner with a PACP version 7.0 exchange database?"

Response: *OWASA will accept CCTV videos in high-resolution MP4 format, accompanied by the most up to date version NASCO Certified Exchange Database.*

2. Question: "Does the Owner have a location to dispose of debris from the sewer cleaning operation? Landfills are not permitted to take material contaminated with wastewater."

Response: *The contractor is responsible for finding a suitable disposal site.*

-END OF DOCUMENT-

