CIP NO.: 378-06
PROJECT: Digester Control Building 2 HVAC Improvement
DATE: September 19, 2025

ADDENDA

ADDENDUM NUMBER 1

DATE: September 19, 2025

PROJECT: Digester Control Building 2 HVAC Improvements Re-Bid

OWASA CIP NUMBER: 378-06

OWNER: ORANGE WATER AND SEWER AUTHORITY

ENGINEER: Wiley|Wilson

TO: Interested Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated June 27, 2025, Addendum Number 1 issued September 19, 2025, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 page:

CHANGES TO THE DRAWINGS:

1. MODIFY Keynote #3 on sheet M-402 to read as follows: “Provide 42” high OSHA compliant galvanized steel or aluminum guard rail.”

ATTACHMENTS

1. None

-END OF DOCUMENT-