CIP NO.: 378-08
PROJECT: Mason Farm Digester #2 Cleaning
DATE: March 13th, 2026

ADDENDA

ADDENDUM NUMBER 01

DATE: March 13, 2026

PROJECT: Mason Farm Digester #2 Cleaning

OWASA CIP NUMBER: 378 - 08

OWNER: ORANGE WATER AND SEWER AUTHORITY

ENGINEER: Brown and Caldwell

TO: RFP Document Plan Holders

This Addendum forms a part of the Contract Documents and modifies the Request For Proposal Documents dated February 2026, Addendum Number 01, issued March 13, 2026, with amendments and additions noted herein below.

Acknowledge receipt of this Addendum in the space provided in the Bid form and return to Engineer. Failure to do so may disqualify the Bidder.

This Addendum consists of 2 pages:

CHANGES TO THE SPECIFICATIONS:

Section 13235 – Digester Cleaning

Article 1.01 Scope of Work, Replace section 10 in its entirety with below:

10. The Contractor shall notify the Owner and Engineer a minimum of one (1) week in advance of the anticipated completion of digester washing and cleaning. Upon completion of cleaning, the Engineer and/or Owner will perform a visual inspection of the interior and exterior of the existing concrete tank to support evaluation of future repairs. The Contractor shall be solely responsible for selecting, furnishing, and providing all means of safe access required for the Engineer and Owner to conduct inspections both inside and outside the digester tank, including access to the full height of the interior and exterior walls. All equipment necessary to provide such access shall be selected at the Contractor's discretion and included in the lump sum bid. Following cleaning, the Contractor shall provide access to the digester interior for up to two (2) of the Owner's employees or authorized representatives for the purpose of tank inspection. The Contractor shall allow up to two (2) full working days for this inspection. No contract work shall occur during the inspection period.

CIP NO.: 378-08
PROJECT: Mason Farm Digester #2 Cleaning
DATE: March 13th, 2026

BID QUESTIONS AND RESPONSES:

1. Will a North Carolina General Contractor License be required?

   Response:

   No, a North Carolina General Contractor License will not be required.

2. Can Engineer provide Engineer's estimated project cost?

   Response:

   Engineer's Estimated Project Cost: $490,000.00

Bidder Acknowledgement _____
Name of Bidder and Date