Orange Water and Sewer Authority

Our community's trusted partner for clean water and environmental protection

ADDENDUM #01

DATE: 3-27-2026

PROJECT: Sykes Street Water Main Replacement Material Only Purchase

OWASA CIP NUMBER: 275-20

OWNER: ORANGE WATER AND SEWER AUTHORITY

TO: ALL SUBMITTERS

This Addendum is to provide answers to questions submitted by Contractors.

Addendum #01 consists of 1 page:

Questions:

1. Can I quote 2" SDR 21 PVC Pipe as an alternative to the SDR 17 PVC Pipe as I have done previously?

   Answer: All bidders should quote the pipe materials listed in the advertisement.

2. What material is the 8" pipe that the 8" x 2" tapping saddle is connecting to? Ductile, C900, etc.?

   Answer: The 8" x 2" tapping saddle will be installed on the existing 8" AC pipe.

3. What are the 2" ProPress fittings going to be installed on? Just out of curiosity, as I don't see any 2" copper pipe requested.

   Answer: The 2" ProPress fittings will be installed on 2" hard-drawn copper pipe, which we currently have in inventory.