ADDENDUM NO. 2
TO
PROJECT MANUAL AND CONTRACT DRAWINGS
FOR
ORANGE WATER AND SEWER AUTHORITY
GRAVITY SEWER REHABILITATION (GSR) PROGRAM, GROUP 1 PACKAGE
(MINI BASIN 23)

Issued: May 13, 2026

To: Official Plan Holders

The following revisions, additions, and clarifications are hereby made part of the Contract Documents for the above-referenced project and shall be taken into account in the preparation of all Bids and the execution of all Work. All items in conflict with the Addenda are hereby deleted. This addendum is made part of the Contract Documents and shall be noted on the proposal.

I. PROJECT MANUAL

Ad-2-I-1. REPLACE Section 00 11 16 with the attached.
Ad-2-I-2. REPLACE Section 00 41 44 with the attached.
Ad-2-I-3. REPLACE Section 01 11 00 with the attached.
Ad-2-I-4. REPLACE Section 01 22 00 with the attached.
Ad-2-I-5. REPLACE Section 01 23 00 with the attached.
Ad-2-I-6. REPLACE Section 33 01 36 with the attached.
Ad-2-I-7. REPLACE Section 33 31 01 with the attached.
Ad-2-I-8. REPLACE Section 40 05 00 with the attached.

II. CONTRACT DRAWINGS

Ad-2-II-1. REPLACE previous drawing set with the attached.

III. QUESTIONS AND ANSWERS

Ad-2-III-1.	Question:	What is the engineers estimate / budget cost?
	Answer:	The Engineer's Opinion of Probable Construction Cost for the base bid work is $2.1M.
Ad-2-III-2.	Question:	Besides 1 hard copy of bid submittal, are there any additional copies required?
	Answer:	Besides the 1 hard copy of the bid submittal, no additional copies are required.
Ad-2-III-3.	Question:	We respectfully request that Global Materials Company be approved as a CIPP liner manufacturer.
	Answer:	Global Materials Company appears to meet the project specifications for CIPP liner manufacturers.

IV. CLARIFICATIONS

Ad-2-IV-1. This addendum modifies the Project Manual to clarify that the base bid includes

service lateral reinstatements on sewer mains renewed with CIPPL and adds add alternate bid 2 for internal service lateral connection seals compatible with CIPPL system on active sewer services.

Ad-2-IV-2. Drawing changes in this addendum consist of adding Riparian buffer zones and base flood elevation zones.

Ad-2-IV-3. The non-mandatory Pre-Bid Conference was held at 3:00 P.M. on April 29, 2026, in the OWASA Administration Offices, 400 Jones Ferry Road, Carrboro, North Carolina. See attached for meeting summary.

Ad-2-IV-4. Quantities provided in the bid form for manhole rehabilitation are estimates. Required manhole rehabilitation work shall be as agreed upon in the field with OWASA's Engineer based on observed condition.

Respectfully submitted,

HDR Engineering, Inc. of the Carolinas

